



Length of supply wire (0,5 mm ² wire cross-section) ¹⁾	Max. meters of LED STRIP at T _a =25°C/2				
	<0,5m	1m	3m	6m	10m
LS PFM-1000/CDB/927/5	7m	6,8m	6,6m	5,8m	5,1m
LS PFM-1000/CDB/930/5	7m	6,8m	6,6m	5,8m	5,1m
LS PFM-1000/CDB/940/5	7m	6,8m	6,6m	5,8m	5,1m
LS PFM-1000/CDB/965/5	7m	6,8m	6,6m	5,8m	5,1m

Pure manual control / Rein manuelle Steuerung¹⁵



Combination manual control and motion detectors /
Kombination manuelle Steuerung und Bewegungsmelder¹⁹⁾



QA - INŽENIRING IN SVETOVALNI INŽENIRING

QA - INŽENIRING IN SVETOVALNI INŽENIRING			
ANTON EREŠ, s.p.		Kosovelova 18, 8250 Brežice	
Objekt:		PRIZIDAVA DOMA KULTURE BREŽICE	
Investitor:		Občina Brežice Cesta prvih borcev 18, 8250 Brežice	
Vrsta projekta: PZI		Vrsta nadzora: Nadzr s področja elektrotehnike	
Vasbino rišbe: KRMILJENJE RAZSVETLJAVE DVORANE			
Ident. št. OP: E-0066		Odgovorni projektant: ANTON EREŠ, udele	
VODUJA PROJEKTA:		Diploma Povetlovc, gradb.teh.	
Datum: marec 2024		Merilo: 1/4	
Št. projekta: 3223/A-18		Št. rišbe: KR-01	
		Identifik. št.: ZAPS 0086	